



October 2, 2026

To All Bidders of A-26-BL-40:

Please note: the following addendum applies to A-26-BL-40 and shall be taken into consideration when preparing bid documents.

General Comment

The Scope of Work is revised. **All work at the Wastewater Treatment Facility is removed from the project.**

Tenderer Questions

The following questions were asked. Included with each is the response.

- .1 Is there a hazmat report?
No, the tender documents for the construction of the original WTF indicate there are no hazardous materials in the existing building.
- .2 What is the proposed finish for the new bathroom floor?
The floor is to be concrete with a floor hardener applied to the finished floor slab.
- .3 Do we have an expected start date?
We anticipate award of contract in early December. Completion date (number of weeks between Contract Award and Substantial Completion is to be indicated by each tenderer.
- .4 Can we have specifications for the existing siding?
The existing siding on the existing building is to be replaced with metal siding as noted on the drawing.
- .5 Can we have specifications on the new 860mm door, frame and hardware?
The new door, frame and hardware are to match the doors in the existing building. The doors and hardware in the original building are specified as hollow metal insulated doors with paint finish, hinges of FBB191 and lockset of 21-8205. Contractor is to confirm existing materials prior to construction.
- .6 Can we have specifications on the new electrical lighting fixture?
The new electrical lighting fixture is to match the fixtures in the existing building. The fixtures in the original building are specified as fluorescent Cooper Metalux VT3. Contractor is to confirm existing materials prior to construction.

A signed copy of each Addendum must also be included with the bid submission. Failure to include this Addendum may be cause for rejection.

ALL OTHER SPECIFICATIONS, TERMS AND CONDITIONS REMAIN UNCHANGED.

Acknowledgement by Bidder:

Company Name: _____

Print Name: _____

Signed: _____

Date: _____

End of Addendum #1