



Addendum #2
WTF & WWTF Upgrades, Bilijik, NS
PROJECT NUMBER A-26-BL-40

PAGE 1
October 2026

October 8, 2026

To All Bidders of A-26-BL-40:

Please note: the following addendum applies to A-26-BL-40 and shall be taken into consideration when preparing bid documents.

General Comment

Revise the "Tender Closing/Opening" date in Article 1.2.1, Section 00 21 13 to October 20, 2026.

Tenderer Question

The following question was asked. Included with it is the response.

.1 Is there additional information on the HVAC?

The HVAC consists of the exhaust fan for the washroom. The fan is to be rated at 50CFM with a noise rating of 0.3 sones. It is to be installed with a wall vent on the west wall of the washroom and ductwork to match the outlet size of the fan.

A signed copy of each Addendum must also be included with the bid submission. Failure to include this Addendum may be cause for rejection.

ALL OTHER SPECIFICATIONS, TERMS AND CONDITIONS REMAIN UNCHANGED.

Acknowledgement by Bidder:

Company Name: _____

Print Name: _____

Signed: _____

Date: _____

End of Addendum #2